

Castle Rock Township Headwall Standards

(To be attached to driveway permit applications)

1. Finished structure shall be below shoulder grade of existing township road.
2. Materials shall be considered breakaway by road authority. Accepted materials shall be keystone like commercially manufactured type blocks, treated 6x6 landscape timbers, field stone up to 10 inches diameter or other like materials.
3. Materials shall not be secured with interlocking devices such as mortar, steel rods, concrete or interlocking blocks.
4. Timbers shall be placed horizontally.
5. Individual wall height shall not exceed 30 inches.
6. Retainage areas exceeding 30 inches shall be reviewed on a case by case basis by the road authority and recommendations made.
7. All efforts shall be made to not impede snow removal, promote road drainage and insure the public safety. The road authority retains the right to act in the best interest of the township and its citizens.